

CERTIFICATE



The **European Certification Body GmbH** accredited
according to ISO/IEC 17065 awards to

TECHNOMAX S.R.L.

Via Casa Bianca, 10, 26037 S. Giovanni in Croce (CR) / IT

the right to carry the ECB•S certification mark for

Light fire storage units of protection level LFS 30 according to EN 15659:2019
and ECB•S C10 (clause 3.1.11)
(Series PRO1 – Types PRO1034K, PRO1044K and PRO1084K)
(see Annex)

Certificate Number

2002/LFS20-01A

10 July 2022

valid from

11 July 2022

Frankfurt am Main

6 May 2025

valid until

Dr. Markus Heering

Certification Body



European Certification Body GmbH
Lyoner Straße 18 • 60528 Frankfurt am Main • Germany
www.ecb-s.com

ANNEX to the certificate No. 2002/LFS20-01A

TECHNOMAX S.R.L., S. Giovanni in Croce / IT

SURVEY – Technical documentation (series PRO1)

TECHNICAL DOCUMENTATION	FILE NAME OF DOCUMENT	DATE	NUMBER OF PAGES
Distributor's agreement form	- - -	13.02.2020	2
Technical documentation according to ECB•S certificate	0906/LFS18-01A	07.05.2021	4

NOTE Only the models corresponding to the listed sizes and which are according to the approved technical documentation of this certificate may be marked with the ECB•S fire certification mark. The marking of the model PRO1034 with the ECB•S fire certification mark is therefore not permitted.

To protect from fires from below it is recommended to anchor the storage units firmly on the floor.

The marking as ECB•S certified product, in compliance with this certificate, is only allowed with an original ECB•S certification mark as proof of conformity according to ISO/IEC 17065.